

**Addendum No. 3**  
**Specifications and Construction Documents**  
*McNeese State University*  
*Contraband Bayou Erosion*  
*Retaining Wall Phase II*  
**FP&C No. 19-627-12-03, Part 01 (F.19001093)**  
**Site Code 5-10-004**  
**M.A. Project No. H1-13015-DA**  
**June 22, 2020**

The following changes, additions, deletions, or alterations to the Specifications and Construction Documents and/or Contract Drawings shall be incorporated into the Specifications and Construction Documents and/or Contract Drawings for the above captioned project:

**A. REFERENCE: Specifications, General Conditions of the Contract for Construction (AIA Document A201-2017), Article 3.12 – Shop Drawings, Product Data and Samples and Construction Documents, Contract Drawing Sheet S-1.1.**

The three (3) required precast concrete piles located in Bent No. 3 of Bridge No. 1 are each 88 feet long. Single pile splices will be allowed in each of these three (3) precast concrete piles. The Contractor shall submit his proposed splice connection device to the Architect/Engineer for approval prior to installation in the form of a Product Data Submittal in accordance with the requirements of the General Conditions of the Contract.

**B. REFERENCE: Specifications, General Conditions of the Contract for Construction (AIA Document A201-2017), Article 3.12 – Shop Drawings, Product Data and Samples and Construction Documents, Contract Drawing Sheet S-3.1.**

The 30” diameter x 93 foot long steel pipe in Bridge No. 3 may be delivered to the site in two (2) pieces and field welded by the Contractor to provide a single 93 foot span.

The Contractor shall submit his proposed field welded connection details to the Architect/Engineer for approval prior to installation in the form of a Shop Drawing Submittal in accordance with the requirements of the General Conditions of the Contract.

**Addendum No. 3**  
**Specifications and Construction Documents**  
*McNeese State University*  
*Contraband Bayou Erosion*  
*Retaining Wall Phase II*  
**FP&C No. 19-627-12-03, Part 01 (F.19001093)**  
**Site Code 5-10-004**  
**M.A. Project No. H1-13015-DA**  
**June 22, 2020**

- C. REFERENCE: Specifications, General Conditions of the Contract for Construction (AIA Document A201-2017), Article 3.7 – Permits, Fees, Notices and Compliance with Laws and Article 3.12 – Shop Drawings, Product Data and Samples.**

In the event the Contractor employs methods of construction which require the installation of temporary structures or devices within the waterway of Contraband Bayou or the East Lateral, the Contractor shall submit Shop Drawings showing the locations, elevations and details of the proposed work within the waterway to the Architect/Engineer and Consolidated Gravity Drainage District No. 2 Calcasieu Parish East, Ward 3 for approval prior to installation in accordance with the requirements of the General Conditions of the Contract.

- D. REFERENCE: Specifications, General Conditions of the Contract for Construction (AIA Document A201-2017), Article 3.12 – Shop Drawings, Product Data and Samples and Construction Documents, Contract Drawing Sheet Nos. S-1.1, S-2.1, S-3.1, S-4.4, and S-6.2 and Addendum No. 1, Item M.**

In low clearance areas under existing utilities at Bridge Nos. 1, 2, and 3 the Contractor may propose to utilize alternative steel sections and members that differ from the specified steel sections shown on the Contract Drawings. The Contractor shall submit details of his proposed alternative steel sections and members to the Architect/Engineer for approval prior to installation in the form of a Shop Drawing Submittal, including drawings and associated calculations, stamped by a Professional Engineer licensed in Louisiana in accordance with General Conditions of the Contract.

MEYER & ASSOCIATES, INC.



Chuck Stutes, P.E.  
Senior Project Director