

ADDENDUM NO. 1

**Hurricane Laura Repairs – Quadrant A, McNeese State University
Lake Charles, Louisiana
Project Number 01-107-05B-13, WBS: F.01004125**

To the Drawings and Specifications dated 10/14/2020:

NOTE:

1. This Addendum shall be considered as part of the original Contract Documents for the above-mentioned Project as though it had been issued at the same time and incorporated integrally therewith. All changes to the work and/or additional work contained herein shall be governed by the requirements of the Contract Documents. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.
2. Bidders are hereby notified that they shall make any necessary adjustments in their bid price on account of this Addendum. It must be acknowledged on the bid form that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.
3. Although additional items may have been discussed during bidding, only items which have been adjusted, added, or removed via addenda are to be made part of the Construction Documents. This includes correspondence made via email. In the absence of changes by Addenda, the provisions of the originally issued construction documents will be required and enforced. If there are any outstanding issues which the bidder feels were discussed and should be added herein, the bidder is encouraged to point these issues out to the Architect prior to the bid date so that action may be considered.
4. Bidders shall acknowledge receipt of this Addendum in the space provide on the Bid Form. Failure to do so shall be sufficient cause for rejection of the Bid.
5. General Contractors are reminded that Bids for this Project are due at 2:00 PM, local time, Friday, October 23, 2020. This is not a revision.

GENERAL

ADG1.1. Pre-Bid Meeting Attendees: The Owner has provided a link to their website that will allow interested parties to view the persons that attended for the Mandatory Pre-Bid Conference held on Friday, October 16, 2020 at the Burton Conference Center on the campus of McNeese State University. The listing will be posted at the bottom of their home page and the link is as follows:

<https://www.doa.la.gov/Pages/ofpc/Index.aspx>

ADG1.2. Project Manual - Louisiana Uniform Public Work Bid Form and Unit Price Form:

A. Delete the current Louisiana Uniform Public Work Bid Form and Unit Price Forms in the Project Manual and replace with the attached Louisiana Uniform Public Work Bid Form and Unit Price Forms, which have been revised. Failure to utilize the attached new Bid Form and Unit Price Forms that are included within this Addendum shall be sufficient cause for the rejection of the Bid.

1. Revisions include the following:

- a) Revisions to quantities of Unit Price 07 52 16 – 01.
- b) Deletion of Unit Price Item 11 40 00-01 on the second to last page
- c) Addition of Unit Price Item 07 52 16–06 on the last page.

2. Refer to updated information included within this Addendum for clarification of several Unit Price descriptions as well as revised description of Unit Price 07 52 16-01 and explanation of addition of new Unit Price 07 52 16-06.
3. Refer to updated information included within this Addendum for clarification of several Unit Price descriptions as well as revised description of Unit Price 09 29 00-01 thru 09 29 00-05 for clarifications of Unit Pricing for these items.

B. Note that as per Article 5.1.2 of the Instruction to Bidders, please make sure that ALL requested Unit Prices are provided and fully extended and are in numerical format. Failure to do so may be sufficient cause for rejection of the Bid.

ADG1.3. Project Manual, General Clarifications and Additional Items:

- A. **Testing Clarification:** Owner will employ services of an independent testing agency to perform specified testing as identified in specifications. Employment of agency in no way relieves contractor of obligation to perform work in accordance with requirements of Contract Documents.
- B. **Provisions for Temporary Systems:** In the event materials and/or systems become unavailable in a timely manner and Contractor is required to provide temporary systems, associated cost will be negotiated via Change Order.
- C. **Insurance Clarifications:**
 1. General Contractor shall furnish Builders Risk Insurance. The policy limits will be based on the total price as bid by the General Contractor and prorated and applied to each building in the respective quadrant.
 2. The General Contractor will be required to provide flood insurance to cover each permanent structure in each quadrant. The campus address is 4205 Ryan St, Lake Charles, LA.
 3. Waivers of Subrogation: The State cannot waive it's right to subrogate due to the negligence of a third party.
 4. Owners – Contractor Protection (OCP). An OCP policy is not required.
- D. **Staging Clarifications:** It is anticipated that the University will provide adequate onsite staging areas in relative proximity to each quadrant's work.
- E. **Food Service Clarification:** No food services will be provided to contractor employees on campus.
- F. **Student / Faculty Activity Clarification:** The General Contractor will be responsible to maintain control and security of the site for the duration of the project. Initially there will be no student or faculty activities going on during the project duration. However, as the project progresses the Owner may call upon the General Contractor to allow partial occupancy and use of the facility. This will be addressed as allowed by the general conditions of the contract. The overarching goal of the project is to allow the reasonable use of the facilities as quickly as possible as portions of the various building become useable for their intended purpose.

1. The intent of this project is for the Contractor to allow partial occupancy (Beneficial Occupancy) of buildings or portions of buildings as they become available for their intended purpose. Substantial completion will be issued when all the buildings in a particular quadrant can be used for their intended purpose. It is acknowledged that the date of Substantial Completion may extend beyond the original contract period and that Liquidated Damages will be considered and may be adjusted accordingly.
- G. **Contractor Parking/ Access Clarification:** The University will allow onsite parking for the construction employees in proximity of the respective Quad's staging area(s). It will be the responsibility of the General Contractor to secure the designated parking and staging areas. Each Contractor and sub-contractor will be required to possess a project specific standardized form of identification for each person, company and vehicle for the duration of the project. The identification shall be visible at all times. Contractor shall be responsible to repair any and all damages to existing parking lots caused by work of this Project.
- H. **Personal/ Research Material Clarification:** The University is currently in the process of having all special personal materials, research material, specimens, biologicals and hazardous materials removed from the work areas. This effort should be complete prior to the General Contractor mobilizing on site. As is customary, should any material of concern be discovered during the course of the work the General Contractor should notify the Architect and Owner. The General Contractor is expected to manage, inventory, document and move all FF&E items that may remain in the building as necessary during the construction process. All items will be documented as being returned to their original location as construction to the respective areas are completed.
- I. **Housing Clarification:** Common-Use Temporary Housing shall be provided for Architects and Engineers of sufficient size and for the exclusive use to accommodate needs of Architect and Engineers only for the duration of the project in order to timely provide responses to questions that may arise in the field during construction. A travel trailer of sufficient size to accommodate 2 individuals is acceptable (approx. 8' wide x 36' long x 11' high). Furnish and equip temporary housing as follows:
1. Two (2) Private bedrooms with furniture required for 1 individual each, including bedding (minimum of queen size bed per individual), a small wardrobe closet, storage under bed, additional storage overhead and a door.
 2. Dinette area with seating for 3 individuals.
 3. Sofa Area
 4. Drinking water and private toilet, combination shower / tub and lavatory.
 5. Full kitchen including microwave oven, range / oven, residential refrigerator, small pantry closet, sink and overhead storage.
 6. Heating and cooling equipment necessary to maintain a uniform indoor temperature of 68 to 72 deg F.
 7. Lighting fixtures
 8. Exterior Steps
- J. **Submittal and RFI Review Clarification:** Design team members will be on site daily as noted in pre-bid meeting. Review of submittals and RFIs will occur as they arrive (or the day of) for an immediate review and response.

- K. **Air Testing and Monitoring Clarification:** Air testing and monitoring cost if required to be provided shall be by Owner.
- L. **COVID Protocols:** Contractor to comply with State of Louisiana, McNeese State University, and/or Contractor Required Protocols associated with COVID. COVID shall not be considered a reason for a delay or force majeure claim.
- M. **Mold Remediation:** The current plan is for the Owner to undertake mold testing and remediation prior to issuing Notice to Proceed to the General Contractor. Note that some testing will still be ongoing upon commencement of the Work and the Contractor will be notified accordingly of the anticipated schedule of those continued testing.
- N. **Long Lead Items:** The intent of this project is to deliver as much of the campus as possible to be in service in the stated contract period. It is acknowledged that some long lead items may not be available in the stated contract period. These items will be addressed on a case-by-case basis and the project schedule and related costs will be adjusted to accommodate these late delivery items.
- O. **Local Building Permits:** Local permits are not required.
- P. **Existing Warranties:** No such information is available at this time. Every effort will be taken to make this information available prior to undertaking any work. The contract may be adjusted accordingly as necessary.
- Q. **Commissioning Consultant:** For the purposes of the Base Bid there will not be a Commissioning Agent retained by the Owner or Contractor for the project.

ADG1.4 Elevator Inspection Reports: Elevator inspection reports as provided by the Owner are included as an attachment to this Addendum. Note that reports for the Parking Garage have not been received as of this date, however it is understood that reports will be made available prior to work commencing.

1. It is anticipated that if the elevator of a particular building is operational it may be used for FFE movement provided that the elevator is properly protected, monitored, and appropriately used in terms of its capacity. Any and all damage received from use will be solely on the General Contractor who shall be responsible for any and all repairs from such damage as caused by movement of FFE items or any other components used in the course of construction Work for this project.

ARCHITECTURAL

ADA1.1. Project Manual Section 01 22 00 – Unit Prices:

A. Article 3.2 Listing of Unit Prices – Paragraph X - Unit Price No. 24 – SBS Modified Bituminous Roofing System to be Removed and Replaced – 075216-01: As clarification the description is revised as follows:

1. Description: Existing double ply roofing system to be removed down to structural decking including all base insulation boards (Assumed average of 4 inches of thickness and/or lightweight insulating concrete). Replace with new SBS Built-up roof system including provision of 4 inches of rigid polyisocyanurate insulation including tapered insulation for proper drainage, including flashing, fascia and roof edge trim, roof penetration flashing, and associated measures for a full FP & C 20 NDL roofing system warranty. The Work shall be done in accordance with the requirements of Division 07 Section “SBS Modified Bituminous Roofing Systems.”

a. Unit of Measure: Per Square Foot.

B. Article 3.2 Listing of Unit Prices – Paragraph C - Unit Price No. 83 – Removal and Replacement of Deteriorated Acoustical Wood Fibered Ceiling Panels – 09 84 33-01: As clarification, revise the Description as follows:

1. Description: The intent of this Unit Price is to address any deteriorated and water damaged acoustical wood fibered ceiling panels that are directly adhered to the underside of the structural roof decking and currently in place but is discovered to be deteriorated and insufficient to remain. Full extent of replacement areas shall be verified with Architect on site prior to beginning any removal and replacement operations. This unit price will be utilized to add to or delete from the quantity of acoustical wood fibered ceiling panels indicated to be addressed in the Base Bid as part of the Work of the Project and shall be done in accordance with the requirements of Division 08 Section “Sound Absorbing Wall and Ceiling Units.”

a. Unit of Measurement: Per Square Foot.

C. Article 3.2 Listing of Unit Prices – Paragraphs BA through BE – Unit Prices 53 through 57 – 09 29 00-01 through 09 29 00-05: As clarification, for these five unit prices, the cost provided for each basic drywall work indicated shall remain unchanged. However, revise the description for the associated painting to include the surface preparation, primer, and two coats of paint to reflect an area of 10 square feet for each square foot of drywall replacement reflected in this Unit Price. As an example, if 32 square feet of drywall has to be replaced in either of these unit prices then include a maximum area of 320 square feet of painting work. If due to existing conditions there is an increased amount of painting to be considered to reach break points for either walls or ceilings then Unit Prices 09 91 23–01 or 09 91 23-2 shall be utilized.

D. Article 3.2 Listing of Unit Prices – Paragraph BD - Unit Price No. 56 – Removal and Replacement of Damaged or Deteriorated Double Layer of Drywall on Ceilings – 09 29 00-04: As clarification, revise the Description as follows:

1. Description: The intent of this Unit Price is to remove any existing damaged or deteriorated double layer of drywall on either wood or metal ceiling framing and replace with new double layer of drywall to match adjacent thickness and fire rating. The intent is that this measurement shall be based upon the actual ceiling surface square footprint square footage area to be removed and replaced and shall reflect the removal and installation of two layers in this Unit Cost. Each layer shall **NOT** be considered as two separate single layers for the surface drywall area quantity but shall be considered as one unit combined into the surface square foot footprint area. Dry and treat exposed framing materials prior to reinstallation. Tape, float, and finish to match adjacent surfaces and textures and as required for fire-rated application. The Work shall be done in accordance with the requirements of respective Division 09 Sections.
 - a. Unit of Measurement: Per Square Foot.

E. Article 3.2 Listing of Unit Prices – Paragraph CA - Unit Price No. 79 – Removal and Replacement of Kitchen Equipment – 11 40 00-01: Delete the Unit Price work item as it will now be listed at Not Applicable on the Bid Form. Any kitchen equipment would be moved by Chartwells.

F. Article 3.2 Listing of Unit Prices – Paragraph CF - Unit Price No. 84 – SBS Modified Bituminous Roofing System to be Removed and Replaced (Multiple Base Roof Systems to be Removed) – 07 52 16-06: Add the following Unit Price.

1. Description: Existing Polyurethane Foam (PUF) roofing system to be removed down to structural decking. Removal includes entire PUF roof system, full thickness (assume 4 inches of thickness) and base layer of original gravel surfaced coal tar roofing system and insulation board. Replace with new SBS Built-up roof system including provision of 4 inches of rigid polyisocyanurate insulation boards including tapered insulation for proper drainage, including flashing, fascia and roof edge trim, roof penetration flashing, and associated measures for a full FP & C 20 NDL roofing system warranty. The Work shall be done in accordance with the requirements of Division 07 Section “SBS Modified Bituminous Roofing Systems.”
 - a. Unit of Measure: Per Square Foot.

ADA1.2 Project Manual, Section 04 01 20.63, Article 3.4: None is anticipated at this time however should this condition be encountered during any repairs it will be addressed via Change order at that time.

ADA1.3 Drawings, Sheets V2.A4.01 and V2.A7.03, Parking Garage: Note that the full cost of repair work to replace the precast wall panels and railing system at this location on the east wall of the Parking Garage shall be included in the Base Bid. There is no Unit Price for this work. Match existing construction.

ADA1.4 Drawings, Sheet V5.A7.03, Holbrook Student Union: Note that the full costs of the masonry repair for the damaged wall as shown in this elevation shall be included in the Base Bid. There is no Unit Price for this work. Match existing construction.

MECHANICAL

ADM1.1. Drawings, Sheets V1–M2.01 thru M2.04 – Note 2: As clarification, flexible ductwork is also intended to be cleaned. If it proves not practical to be cleaned then it shall be replaced.

ADM1.2. Drawings, Sheet V3-M2.01 – Note 2: As clarification, it is intended that all grille accessories (dampers, vanes, etc.) shall be cleaned. It is anticipated that all of these items shall be considered as operable so price cleaning of all components. If any component is determined to be non-working, it will be addressed at that time during construction.

ADM1.3. Drawings, Sheet V3.M205 – Note 2: As clarification, all existing duct accessories shall be replaced in the ducts that are being replaced.

ADM1.4. Drawings, Sheets V5.M201, V6.M201, 202 and 203 – Note 2: As clarification, all existing duct accessories shall be replaced in the ducts that are being replaced.

ELECTRICAL

ADE1.1. Drawings, General:

1. As clarification, if there are electrical panels that are shown on Drawings in repair areas but are NOT listed in the Keynotes, the intent is that these panels are NOT to be replaced under the current scope of Work.
2. As clarification, there will be NO access controls or cameras that will be replaced under the current scope of Work.
3. As clarification, the auditorium in Hardtner Hall has speakers and microphones shown on the Drawings in repair areas. These items are NOT intended to be replaced under the current scope of work
4. As clarification, the gear shown to be replaced in the pool building currently is indicated to be SQD. Equivalent manufacturers/products will be considered as acceptable.

ADE1.2. Drawings, Sheet V5.E2.01 (Holbrook): Add the following to the light fixture schedule on this sheet:

1. **Emergency Light Fixture:** Manufacturer EXITRONIX Catalog number NFT(2) 2.7W LED Lamps-White.
2. **Exit light fixture:** Manufacturer EXITRONIX Catalog number 400U1-WB-WH

ADE1.3. Drawings, Sheet V6.E2.01 (Student Union Annex): Add the following to the light fixture schedule on this sheet:

1. **Emergency Light Fixture:** Manufacturer EXITRONIX Catalog number NFT(2) 2.7W LED Lamps-White.

ADE1.4. Project Manual and Drawings:

1. **Fire Alarm Systems:** As clarification, Contractor shall include the testing of the existing system by a licensed fire alarm sub-contractor within their Base Bid.. Pending the resolution of the testing, the necessary repairs to the system that are in addition to those items already indicated on the Drawings will be addressed by Change Order.
 - a. Contractor shall include in their Bid all fire alarm devices which are currently shown on the Drawings to be replaced.
2. **Tele Communications Systems:** As clarification, Contractor shall test the building's telecom systems and provide the Architect and Engineer with a list of all items and devices needing repair or replacement. Contractor shall include in their Bid all telecom devices which are currently shown on the Drawings to be replaced.

PRIOR APPROVED SUBSTITUTIONS

Prior-Approved Substitutions as listed below shall be equal to those specified in every respect. The design team takes no objections to the brand names of the substitutions listed. Required submittals during construction phase services shall illustrate each substitution's compliance with the contract documents.

Contractor shall note that prior approval is by manufacturer's name only. Contractor shall ensure that the products used in preparation of his proposal and proposed to be used on this project is equivalent to that specified including: appearance, performance, size, installation type, shape, etc. Any material later found to not be equivalent to that specified will be rejected. Prior-approval of one manufacturer does not automatically approve any subsidiary company, parent company and/or "sister" company's respective products.

Description of Prior Approval Item:

Type	Manufacturer
Variable Air Volume Box	Johnson Controls
Fan Coil Units	Johnson Controls

END OF ADDEDNDUM NO. 1.

Attachments:

1. Elevator Reports immediately following this Page.
2. Revised Louisiana Uniform Public Work Bid Form and Louisiana Uniform Public Work Bid Form Unit Price Form immediately following the Elevator Reports

ELEVATOR REPORTS AS PROVIDED BY OWNER

S.E.E.D Crt.

Unit 1 & 2

Cleared all faults

Reset units and returned to service

Pits clear

Car top clear

Chozen Hall

Checked walls and roof

Pits clear

Car top clear

Reset all faults

Returned to service

Kaufman Hall

Found blown Main Fuse

Replaced F50 and FLS

Cleared all Faults

Unit is back in service

Pit has Water and Oil mixed – it needs to be pumped out in drums for proper disposal

Kirkman Hall

Unit 1: DMC

Unit needs cleaning and sheetrock repair in hoist

Wall damaged from storm

Machine room walls had heavy Mold (see pic)

The Unit is a Dover 4 slot - Unit is Obsolete per manufacturer
as of Nov 17th 2019

It is my suggestion the Unit needs to be upgraded.

Unit 2: Otis Freight

Needs new prints

Pit was wet - needs blowers to dry out

Reset S1 for the J circuit to pick up

Ran unit and returned to service

Hardtner Hall

No water in pit

Found doors separated on 2nd FL

Work crew is cleaning

Emergency Light Battery needs replacing

Burton Dorm

Pit clean

C/T clean

Cleared Faults

Unit in service upon arrival

SFA

Dover DMC 4 slot

No water in Machine Room

Main power was on - The 110 is still off

Replaced Main fuses 1/2/3

Reset faults

Unit needs Emg Batt replaced

Left unit off line till Power restored

The outside door to the M/R is damaged

The Unit is a Dover 4 slot - Unit is Obsolete per manufacturer
as of Nov 17th 2019.

It is my suggestion the Unit needs to be upgraded.

SFAA

Pit clean

C/T clean

Unit in service

No damage found

Drew Hall

(see pic)

Pit had water – built in sump pump cleared water but pit needs blowers to complete drying out

Water came from top floor

Door operator is not working on HI speed - water on motor and drive – unable to fully diagnose, possible short

C/T controller is also water damaged

Interlocks and door equipment are rusted - including hangers, rollers, pickups, door tracks and gate switch

The main rails on the right side are rusted and need resurfacing
3rd fl buttons and access switch need to be removed for work crew to remove damaged sheetrock

The vent in the top of shaft is damaged and leaking water

Unit was left in IND(independent) service for work crew

Can not return unit to full service until repairs are made

Frasch

Unit #2

Pit clear of water

C/T Dry

No wall or roof damage

This is an old Montgomery that has been written up for repairs or MOD. The rubber hose on the Hydro line is not in code.

(see pic)

Unit #1

No power on unit

Water in Pit

Water from the 3rd Fl ran down the hoistway

We will need to replace the door interlocks and closers from the 3rd FL down to ground level. The door tracks will need to be cleaned and/or possibly replaced. The rest of the hoistway will need to be checked when power is restored.

BBC

2 Units (duplex)

Pit had some water in it – the sump pump cleared the water in the pit. Blowers are needed to completely dry the pit.

C/T clear

M/R clear

Emergency light battery needs to be replaced in both units

HHP – 3 MRL UNITS

No power in building

Pits are full of water

The water is over the Gov tail sheaves. The sheaves and cables need replacing. The GFCI plug is under water, the plug and wire will both need to be replaced.

Only one unit was at ground floor when flooding occurred. We will need to check flooring in that unit when power is restored. The unit will need power to move it from 1st floor so the water can be pumped out and repairs can begin.

Motors and main equipment are in the top of the hoistway – there is no visible damage; however, I am currently unable to make a full assessment until the units are running and I can access the units from the top of the car.

Gayle

No power in building

Pit was full of water

Tank is Obsolete

The water damage to the door equipment, door operator, top of car box and COP is extensive.

Due to lack of power, I was unable to completely check the unit during initial inspection. Based on the damage I viewed during my limited inspection, the unit will need a complete MOD.

Once the power is restored I will do a detailed inspection on the unit to ascertain the extent of the damage.

REC

Pit is clean

M/R is great

Cleared faults

Unit is running

No damage to report for this unit

Frazar Library

No power in building

Hydro is an older unit with front and rear openings

We will need to check unit when power is restored.

Initial inspection found surface rust on door equipment but unable to check functionality and extent of damage until power is back on.

The two traction units are damaged beyond repair.

I would completely replace both units with a full MOD - including new Hollister Whitney machines.

The main rails and the counter-weight rails can be reused.

The counter-weights and platform can be reused with the installation of new sub floors. (see pic)

STAD

No power

Wall down in machine room

Units have significant damage

Both units have interior water damage - they will need to have the sub floor, interior cab walls and lighting replaced

The units will need a complete MOD

The machine may be able to be rebuilt and not have to be replaced

The brakes and motor will need to be replaced if the machine is retained.

(see pic)

Farrar

No power

M/R roof is gone

Water in pit

Water on cartop

Water in car and COP

This unit will require a full MOD

(see pic)

LOUISIANA UNIFORM PUBLIC WORK BID FORM

TO: State of Louisiana—Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095.
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

The undersigned bidder hereby declares and represents that she/he; a) has carefully examined and understands the Bidding Documents, b) has not received, relied on, or based his bid on any verbal instructions contrary to the Bidding Documents or any addenda, c) has personally inspected and is familiar with the project site, and hereby proposes to provide all labor, materials, tools, appliances and facilities as required to perform, in a workmanlike manner, all work and services for the construction and completion of the referenced project, all in strict accordance with the Bidding Documents prepared by: ACSW ARCHITECTS, LLC, 115 EAST MAIN STREET, LAFAYETTE, LA and dated OCTOBER 14, 2020.
(Owner to provide name of entity preparing bidding documents.)

Bidders must acknowledge all addenda. The Bidder acknowledges receipt of the following **ADDENDA:** (Enter the number the Designer has assigned to each of the addenda that the Bidder is acknowledging) _____.

TOTAL BASE BID: For all work required by the Bidding Documents (including any and all unit prices designated “Base Bid” * but not alternates) the sum of:
_____ Dollars (\$ _____)

ALTERNATES: For any and all work required by the Bidding Documents for Alternates including any and all unit prices designated as alternates in the unit price description.

Alternate No. 1 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:
_____ NOT APPLICABLE Dollars (\$ _____ NOT APPLICABLE _____)

Alternate No. 2 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:
_____ NOT APPLICABLE Dollars (\$ _____ NOT APPLICABLE _____)

Alternate No. 3 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:
_____ NOT APPLICABLE Dollars (\$ _____ NOT APPLICABLE _____)

NAME OF BIDDER: _____

ADDRESS OF BIDDER: _____

LOUISIANA CONTRACTOR’S LICENSE NUMBER: _____

NAME OF AUTHORIZED SIGNATORY OF BIDDER: _____

TITLE OF AUTHORIZED SIGNATORY OF BIDDER: _____

SIGNATURE OF AUTHORIZED SIGNATORY OF BIDDER **: _____

DATE: _____

THE FOLLOWING ITEMS ARE TO BE INCLUDED WITH THE SUBMISSION OF THIS LOUISIANA UNIFORM PUBLIC WORK BID FORM

* The Unit Price Form shall be used if the contract includes unit prices. Otherwise it is not required and need not be included with the form. The number of unit prices that may be included is not limited and additional sheets may be included if needed.

** **A CORPORATE RESOLUTION OR WRITTEN EVIDENCE** of the authority of the person signing the bid for the public work as prescribed by La. R.S. 38:2212(B)(5) .

BID SECURITY in the form of a bid bond, certified check or cashier’s check as prescribed by LA RS 38:2218.A is attached to and made a part of this bid.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ General Building Cleaning and Removal of Interior Debris			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
01 77 00-01	80,000	SQUARE FOOT		

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Deteriorated Acoustical Wood Fibered Ceiling Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 84 33-01	3,800	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Exterior Wall Brackets			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
05 50 00-01	12	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Reattachment and Alignment of Damaged Exterior Metal Railing			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
05 50 00-02	4	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Existing Flagpoles			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
05 50 00-03	2	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated Wood Blocking/Nailers			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 10 00-01	2,500	BOARD FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated Structural Wood Decking			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 15 00-01	4,000	BOARD FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated Plywood Decking			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 16 00-01	2,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Fascia Trim to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 20 13-01	500	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Plywood/Wood Vinyl Soffit			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 20 13-02	100	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Plywood/Wood Soffit to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 20 13-03	100	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Damaged Covered Pavilion			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06 20 13-04	1,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Closed Cell Sprayed Insulation			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 21 19-01	10,500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Asphalt Shingle Roofing			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 31 13-01	9,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Standing Seam Metal Roof Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 41 13-01	5,000	SQUARE FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Standing Seam Metal Roof Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 41 13-02	27,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Concealed Fastener Metal Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 13-01	800	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Concealed Fastener Metal Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 13-02	600	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Exposed Fastener Metal Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 13-03	200	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Exposed Fastener Metal Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 13-04	100	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Vinyl Soffit			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 93-01	200	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Vinyl Soffit to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 42 93-02	100	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ SBS Modified Bituminous Roofing System to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16-01	85,000	SQUARE FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Lightweight Insulating Concrete Deck - Areas of Replacement and Infill Patching			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16-02	10,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Metal Deck Removal and Replacement/Multi Span			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16-03	500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Roof Drain Replacement			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16-04	10	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Add Interply Roofing Membrane Sheets to Eliminate Ponding at Interply			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16-05	1,500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Aluminum Fascia and Trim			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 62 00-01	100	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Metal Gutter to be Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 62 00-02	300	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Metal Gutter to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 62 00-03	200	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# _____ Metal Downspout to be Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 62 00-04	300	LINEAR FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Metal Downspout to be Removed and Replaced			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 62 00-05	100	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Domed Skylight			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 72 00-01	2	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Roof Access Hatch			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 72 00-02	2	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated Window and Door Sealant			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 92 00-01	2,000	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Solid Core Wood Door			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 14 16-01	4	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Overhead Coiling Door			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 33 23-01	250	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Storefront Framing and Window System			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 41 13-01	350	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Interior Aluminum Window Trim			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 41 13-02	200	LINEAR FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Curtainwall Framing and Window System			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 44 13-01	500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replace Missing Door Closer			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 71 00-01	4	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replace Missing Door Weatherstripping – Single Door			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 71 00-02	20	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replace Missing Door Weatherstripping – Double Door			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 71 00-03	5	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Single Pane Glazing			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 80 00-01	75	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Damaged Insulated Glazing			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08 80 00-02	100	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Cleaning of Hard Flooring and Resilient Flooring Surfaces			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 00 00-01	75,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Cleaning of Carpet and Carpet Tile			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 00 00-02	25,000	SQUARE FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Cleaning of Walls			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 00 00-03	50,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated or Missing 4” Metal Studs			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 22 16-01	200	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Deteriorated or Missing 6” Metal Studs			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 22 16-02	100	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Repair of Missing or Damaged Exterior Plaster/Stucco Finish System			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 24 00-01	2,500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Damaged or Deteriorated Drywall on Walls			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 29 00-01	5,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Drywall on Walls			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 29 00-02	15,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Damaged or Deteriorated Single Layer of Drywall on Ceilings			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 29 00-03	10,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Damaged or Deteriorated Double Layer of Drywall on Ceilings			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 29 00-04	32,000	SQUARE FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Drywall on Ceilings			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 29 00-05	1,500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing 24” x 24” Acoustical Ceiling Tile			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 51 13-01	24,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing 24” x 48” Acoustical Ceiling Tile			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 51 13-02	8,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing 24” x 24” Acoustical Ceiling Tile and Suspension System			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 51 13-03	80,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing 24” x 48” Acoustical Ceiling Tile and Suspension System			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 51 13-04	10,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Removal and Replacement of Damaged Resilient Base			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 65 13-01	2,000	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Resilient Base			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 65 13-02	8,000	LINEAR FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ____ Replacement of Missing Stair Nosing and Tread			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 65 13-03	100	LINEAR FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.
 All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Removal and Replacement of Damaged LVT Flooring			
REF. NO.	UNIT PRICE	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 65 19-01	8,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Replacement of Missing LVT Flooring			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 65 19-02	1,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Replacement of Missing Resilient Athletic Flooring			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 65 66-01	7,200	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Removal and Replacement of Damaged Broadloom Carpet and/or Carpet Tile			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 68 13-01	16,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Replacement of Missing Broadloom Carpet or Carpet Tile			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 68 13-02	2,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Removal and Replacement of Damaged or Deteriorated Acoustical Wood Fibered Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 84 33-02	2,500	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Removal and Replacement of Damaged or Deteriorated Acoustical Ceiling Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 84 33-03	8,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# Removal and Replacement of Damaged or Deteriorated Acoustical Wall Panels			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (<i>Quantity times Unit Price</i>)
09 84 33-04	3,000	SQUARE FOOT		

Wording for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana–Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Painting of Walls			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 91 23-01	30,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Painting of Ceilings			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 91 23-02	10,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Removal of Existing Vinyl Wall Covering/Paint Walls			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 91 23- 03	40,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Repairs of Existing Plaster/Stucco Surfaces			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09 91 23-04	1,800	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Replacement of Existing Fire Extinguisher Cabinet and Fire Extinguisher			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
10 14 00-01	12	EACH		

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Staging of Existing Light Duty Furniture Fixtures and Equipment			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
12 50 00-01	95,000	SQUARE FOOT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Staging of Existing Specialty or Heavy Duty Furniture Fixtures and Equipment			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
12 50 00-02	3,800	SQUARE FOOT		

Wordings for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

UNIT PRICE FORM

TO: State of Louisiana—Division of Administration
Office of Facility Planning and Control
Claiborne Office Building
1201 North Third Street Post Office Box 94095
Baton Rouge, LA 70804-9095
(Owner to provide name and address of owner)

BID FOR: Hurricane Laura Repairs – Quadrant A
McNeese State University
Lake Charles, LA
Project No: 01-107-05B-13 WBS: F.01004125
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Removal and Replacement of Fixed Auditorium Seating			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
12 50 00-03	270	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Refurbishment of Existing Elevator			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
14 24 00-01	2	EACH		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Modified Bituminous Roofing Systems to be Removed and Replaced (Multiple Base Roof Systems to be Removed)			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07 52 16 - 06	63,000	SQUARE FOOT		

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# ___ Not Applicable			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable

Wording for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.